

Bid#26-007 TSPLOST Milling & Resurfacing Year 5

Addendum #4

1. The pay item for crosswalks is listed as preformed plastic tape. This material is intended to be installed on concrete surfaces, however; the existing crosswalks appear to be on asphalt. I believe this item is being used in error and should be thermoplastic. **Thank you for bringing this to our attention. Yes this should have been thermoplastic.**
2. Will the contractor be required to haul the millings to the City? **No. It will be the contractors responsibility to dispose of the millings.**
3. Will Railroad Insurance Be required for this project? **Railroad insurance will not be required. The contractor will need to stay out of the railroad limits.**