

Question:

Regarding the Sodium Fluorosilicate, I only see it listed in the Excel document, not the PDF for the bid. I wanted to confirm if this is part of the solicitation and if you have your specification requirements for it on hand.

Answer:

It is part of the solicitation. It must be NSF approved for drinking water.